




MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2025/D-1183

Dated- 09/06/25

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - Dwarka International School
2. SCHOOL ADDRESS:- Sec-12, Dwarka New Delhi-110078.
3. NO. OF SHIFT. ONE TIMING Morning. 08:00 AM TO 02:20 PM
4. NO. OF STUDENTS: BOYS- 1308 GIRLS – 926 TOTAL = 2234
5. NO. OF STAFFS: MALE - 16 FEMALE – 89 TOTAL = 105

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student


1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard

Note:- (Basement + GF + 3UF)

Deputy Health Officer
Deputy Najafgarh Zone Officer
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)





DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



International Year
of Cooperatives

Water Sample Analysis report of samples collected from Dwarka International School, Sector- 12, Dwarka, New Delhi-110078 Vide Challan No. 138 Dt-26.08.2025.

S1:- DJB Supply

THE TEST REPORT IS
FOR THIS PARTICULAR

S2:- Drinking Point (R.O)

S. No.	Particulars	WATER SAMPLE ONLY.	Limit		S1	S2
			Acceptable	Permissible		

PHYSICAL EXAMINATION

1.	Date of collection	-----	--	--	28.08.2025	28.08.2025
2.	Date of Analysis	-----	--	--	30.08.2025	30.08.2025
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.8	1.0
6.	PH value	-----	6.5	8.5	7.64	7.60
7.	Electrical Conductivity	µmho/cm	--	--	236.5	241.1
8.	Total dissolved solids	mg/l	500	2000	153.7	156.7

CHEMICAL EXAMINATION

9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	76	72
11.	Total Hardness	mg/l	200	600	98	100
12.	Calcium Hardness	mg/l	--	--	66	70
13.	Magnesium Hardness	mg/l	--	--	32	30
14.	Calcium as Ca	mg/l	75	200	26.4	28.0
15.	Magnesium as Mg	mg/l	30	100	7.68	7.20
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	2.8	3.0
19.	Sulphate	mg/l	200	400	22	24
20.	Chloride	mg/l	250	1000	18	20
21.	Fluoride	mg/l	1	1.50	0.22	0.24
22.	Dissolve Iron	mg/l	1	N.R.	0.12	0.10
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.60	NIL


BACTERIOLOGICAL EXAMINATION

25.	Coli-form per 100 ml at 37°C	MPN	0	0	0
-----	------------------------------	-----	---	---	---

REMARKS:- As per tested parameters Sample - S1 & S2 can be used for drinking purpose.

S. S. S. S. S.
ACWA
Asstt. Chief Water Analyst
Delhi Jal Board Analyst
G. DELHI JAL BOARD
Govt. of N.C.T. Delhi
Water Quality Laboratory
Nangloi, Delhi-41

Hemlal
CHEMIST



BACT.